



STATE OF UTAH
DEPARTMENT OF HEALTH

FILE
PNO/023/007

SCOTT M. MATHESON, GOVERNOR

MICHAEL J STAPLEY, M.P.A., ACTING EXECUTIVE DIRECTOR

February 11, 1985

RECEIVED

FEB 13 1984

Mr. Dave Hooper, Reclamation Hydrologist
Division of Oil, Gas & Mining
3 Triad Center, Suite 350
Salt Lake City, Utah 84180-01203

DIVISION OF OIL
GAS & MINING

Re: North Lily Project, Juab County

Dear Mr Hooper:

We have examined the materials submitted to us regarding the above referenced project. It would appear that cyanide wastewaters will not be a problem since the tailings will be treated and neutralized with NaOCL and the process water will be totally recycled or sent to the refinery with the concentrate. However, we still must review any wastewater handling facilities including runoff control structures for the mill site, the untreated tailings and the spent tailings placement areas. The spent tailings has the possible inclusion of cyanides due to the break down or malfunction of the neutralization facilities.

The sanitary waste facilities, if less than 5000 gallon per day, must be approved through the Central Utah District Health Department.

If you have questions regarding the information needs we perceive for our review and approvals please contact me at this office.

Sincerely,

Brian L. Nelson
Environmental Engineer
Bureau of Water Pollution Control

pa

cc: Central Utah Health Dist.

385-3

0001